

CONSUMER CONFIDENCE REPORT TCEQ CERTIFICATE of DELIVERY

For Calendar year 2017

Public Water System (PWS) Name: City of Willow Park, TX

PWS ID Number: TX1840027

I certify that the community water system named above has distributed the Consumer Confidence Report (CCR) for the calendar year of 2017 and that the information in the report is correct and consistent with the compliance monitoring data previously submitted to the TCEQ. Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL.

Date of Delivery: 6-11-18

Certified By:

Name (print): Ramon Johnson

Title:

Public Works Director

Phone Number: 817-441-7708

Signature: 

Date: 6-11-18

You must use at least one direct delivery and at least one good faith delivery method:
(indicate "☑" all that apply):

Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL here: http://www.willowpark.org

Direct Delivery Methods

- ☒ Mail a paper copy of the CCR
- ☐ Mail notification that CCR is available on-line at http://_____
- ☐ *The Internet link (url) you insert above **must** take customers directly to the open CCR.
- ☐ Email direct web address of the CCR, available at http://_____
- ☐ Email CCR as an attachment to or an embedded image in an email.
- ☐ Other direct delivery (for example, door hangers or additional electronic delivery method).
Please specify: _____

Good faith delivery methods - To reach people who do not receive bills (check all that apply):

- ☒ Posting the CCR on the Internet at http://_____
- ☐ Mailing the CCR to people who receive mail, but who do not receive bills.
- ☐ Advertising the availability of the CCR in news media.
- ☐ Posting the CCR in public places.
- ☐ Delivering multiple copies to single billing addresses serving multiple persons.
- ☐ Delivering multiple copies of the CCR to community organizations.

All systems are required to mail by July 1 the Certificate of Delivery and complete Consumer Confidence Report to:

Sending by certified mail:	Sending by regular mail:
TCEQ DWSF, MC-155, Attn: CCR, 12100 Park 35 Circle Austin, TX 78753	TCEQ DWSF, MC-155, Attn: CCR, PO Box 13087 Austin, TX 78711-3087

2017 Consumer Confidence Report for Public Water System CITY OF WILLOW PARK

This is your water quality report for January 1 to December 31, 2017

CITY OF WILLOW PARK provides surface water and ground water from Paluxy and Trinity] located in Parker Count.

Definitions and Abbreviations

Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppq	parts per quadrillion, or picograms per liter (pg/L)

Definitions and Abbreviations

ppt

parts per trillion, or nanograms per liter (ng/L)

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name		Type of Water	Report Status	Location
1 - INDIAN CAMP / LAKE VIEW	INDIAN CAMP / LAKE VIEW	GW	<u>A</u>	<u>paluxy</u>
10P - SURREY LN	SURREY LN	GW	<u>A</u>	<u>paluxy</u>
10T - SURREY LN		GW	<u>A</u>	<u>paluxy</u>
11 - SQUAW CREEK RD	SQUAW CREEK RD	GW	<u>A</u>	<u>paluxy</u>
12 - SW OF SHERWOOD CIR	SW OF SHERWOOD CIR	GW	<u>A</u>	<u>paluxy</u>
13 - ROYAL VIEW DR / KNIGHTS BRIDGE	ROYAL VIEW DR / KNIGHTS	GW	<u>A</u>	<u>paluxy</u>
14 - INDIAN CAMP / CROWN RD	INDIAN CAMP / CROWN RD	GW	<u>A</u>	<u>Trinity</u>
15 - INDIAN CAMP / CROWN RD	INDIAN CAMP / CROWN RD	GW	<u>A</u>	<u>paluxy</u>
16P - 1109 FOX HUNT TRL	1109 FOX HUNT TRL	GW	<u>A</u>	<u>Trinity</u>
16T - 1109 FOX HUNT TRL	1109 FOX HUNT TRL	GW	<u>A</u>	<u>paluxy</u>
17 - PS 1 / QUAIL CREST	PS 1	GW	<u>A</u>	<u>paluxy</u>
18 - PS 1 / QUAIL CREST	PS 1	GW	<u>A</u>	<u>paluxy</u>
2 - E LAKE DR	E LAKE DR	GW	<u>A</u>	<u>paluxy</u>
20 - PS 2 (WILLOW SPRINGS / OAKS	PS 2 (WILLOW SPRINGS / OAKS	GW	<u>A</u>	<u>paluxy</u>
3 - E LAKE DR	E LAKE DR	GW	<u>A</u>	<u>paluxy</u>
4 - E LAKE DR / CREST RD	E LAKE DR / CREST RD	GW	<u>A</u>	<u>paluxy</u>
5 - INDIAN CAMP	INDIAN CAMP	GW	<u>A</u>	<u>paluxy</u>

6P - RIDGE RD	RIDGE RD	GW	A	paluxy
6T - RIDGE RD	RIDGE RD	GW	A	trinity
7 - WHITE SETTLEMENT RD	WHITE SETTLEMENT RD	GW	A	paluxy
9 - RANCH HOUSE RD	RANCH HOUSE RD	GW	A	paluxy
EL CHICO P		GW	A	paluxy
EL CHICO T		GW	A	paluxy
WILLOW SPRINGS OAK		GW	A	paluxy

may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact [insert water system contact][insert phone number]

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/22/2015	1.3	1.3	0.19	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/22/2015	0	15	3.5	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

2017 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAAS)	2017	4	0 - 4.4	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'

Total Trihalomethanes (TTHM)	2017	20	5.01 - 19.8	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'

Inorganic Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2017	0.1	0.072 - 0.1	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2017	6.7	4.2 - 6.7	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2017	0.706	0.222 - 0.706	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2017	0.328	0 - 0.328	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	05/16/2016	3.36	0.9 - 3.36	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	05/16/2016	9.2	4 - 9.2	0	15	pCi/L	N	Erosion of natural deposits.
Uranium	05/16/2016	1.1	0 - 1.1	0	30	ug/l	N	Erosion of natural deposits.

Disinfectant Residual

' A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQOR).'

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine (Free)	2017	1.00	.91-1.49	4	4	mg/L	y	Water additive used to control microbes.

Violations

Public Notification Rule

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).

Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	04/15/2015	01/03/2017	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.